



**JOINT ELECTRICITY REGULATORY COMMISSION  
FOR MANIPUR AND MIZORAM  
AIZAWL : : : MIZORAM**

TBL Bhawan, 2<sup>nd</sup> – 5<sup>th</sup> Floor, E – 18, Peter Street, Khatla Aizawl, Mizoram-796001  
Tel. No. : 0389-2336555 / 2335625, Fax: 0389-2336299 / 2335523  
Website : [www.jerc.mizoram.gov.in](http://www.jerc.mizoram.gov.in), Email : [jerc.mm@gmail.com](mailto:jerc.mm@gmail.com)

**NOTIFICATION**

**Dated, Aizawl the 17<sup>th</sup> July, 2019**

**No. H. 11019/3/18-JERC:** In exercise of powers conferred under Section 50 read with Clause (x) of Sub-section (2) of Section 181 of the Electricity Act, 2003 (36 of 2003), and all other powers enabling it in this behalf, the Joint Electricity Regulatory Commission for Manipur & Mizoram hereby makes the following Regulations to amend the Joint Electricity Regulatory Commission for Manipur & Mizoram (Electricity Supply Code) Regulations, 2013 (hereinafter referred to as “the Principal Regulations”), namely;

**1. *Short title and commencement***

- (1) This Regulation may be called the Joint Electricity Regulatory Commission for Manipur & Mizoram (Electricity Supply Code) (Thirteenth Amendment) Regulations, 2019.
- (2) This Regulation shall extend to the whole States of Manipur and Mizoram and shall apply in relation to all matters falling within the jurisdiction of the Commission.
- (3) This Regulations shall come into force from the date of their notifications in the Official Gazette of the concerned States.

**2. *Amendment in Regulation 3 of the Principal Regulations:***

Clause 3.1(2) of the Joint Electricity Regulatory Commission for Manipur and Mizoram (Electricity Supply Code) Regulations, 2013 shall be substituted as below:

- 3.1(2) At the point of commencement of supply, except with the written consent of the consumer or with the previous sanction of the Commission, a supplier shall not permit the voltage to vary from the declared voltage more than stipulated below or the limit specified by Central Electricity Authority from time to time.

(a) Plus(+)/Minus(-) 6% in respect of Low Tension.

**i.e. (1) Single phase supply**

**Minimum: 216V (phase to neutral)**

**Maximum: 244V (phase to neutral)**

**(2) 3 phase supply**

**Minimum: 376V (phase to phase)**

**Maximum: 424V (phase to phase)**

(b) Plus(+)/Minus(-) 9% in respect of High Tension.

**i.e. (1) 11kV system**

**Minimum: 10kV (phase to phase)**

**Maximum: 12kV (phase to phase)**

**(2) 33kV system**

**Minimum: 30kV (phase to phase)**

**Maximum: 36kV (phase to phase)**

(c) In respect of Extra High Tension.

**i.e. (1) 132kV system**

**Minimum: 122kV (phase to phase)**

**Maximum: 145kV (phase to phase)**

**(2) 400kV system**

**Minimum: 380kV (phase to phase)**

**Maximum: 420kV (phase to phase)**

**Provided that even if the state transmission licensee/utility does not receive regulated voltage from the inter-state transmission licensee/utility, it shall be the duty of the state transmission licensee to deliver regulated voltage to the distribution licensee/utility within the specified limits and it shall be the duty of distribution licensee/utility to deliver regulated voltage to the consumer within the specified limit in the licensed area of operation.**

By Order of the Commission

Sd/-RICHARD ZOTHANKIMA  
Assistant Secretary